




MINIMUM DISTANCE BETWEEN TOWERS AND OBSTRUCTIONS COMPLETE CONFIGURATION



MODEL	BETWEEN TOWERS		ONE WALL		TWO WALLS		THREE WALLS (A)		THREE WALLS (B)	
	SHORT SIDE "DW"	LONG SIDE "DL"	SHORT SIDE "DW"	LONG SIDE "DL"	SHORT SIDE "DW"	LONG SIDE "DL"	SHORT SIDE "DW"	LONG SIDE "DL"	SHORT SIDE "DW"	LONG SIDE "DL"
505	6	6	3	3	3	3	3	3	3	3
606	6	6	3	3	3	3	3	3	3	3
707	6	6	3	3	3	3	4	3	4	3
808	6	6	3	3	3	3	4	3	4	3
810	6	6	3	3	3	3	4	3	5	3
812	6	6	3	3	3	3	5	3	5	3
510	6	6	3	3	3	3	3	3	3	3
612	6	6	3	3	3	3	4	3	4	3
714	6	6	3	3	3	3	4	3	5	3
816	6	6	3	3	3	4	5	4	5	3
819	6	6	3	3	3	4	6	4	5	3
822	6	7	3	4	3	4	5	4	6	3
827	6	8	3	4	3	5	6	5	6	3
1010	6	6	3	3	3	3	5	3	5	3
1212	6	6	3	3	4	4	6	4	6	4
1414	7	7	4	4	5	5	7	5	7	5
1616	8	8	4	4	5	5	8	5	8	5
1619	9	8	5	4	6	6	9	6	8	6
1622	8	10	4	5	6	7	8	7	9	6
1627	9	12	5	6	6	7	9	7	9	6
707-SL	6	6	3	3	3	3	4	3	4	3
808-SL	6	6	3	3	3	3	4	3	4	3
810-SL	6	6	3	3	3	3	4	3	4	3
812-SL	6	6	3	3	3	3	4	3	5	3
714-SL	6	6	3	3	3	3	4	3	5	3
816-SL	6	6	3	3	3	4	5	4	5	3
819-SL	6	6	3	3	3	4	6	4	5	3
822-SL	6	6	3	3	3	4	5	4	5	3
827-SL	6	7	3	4	3	5	5	5	6	3
1414-SL	7	7	4	4	5	5	7	5	7	5
1616-SL	8	7	4	4	5	5	7	5	7	5
1619-SL	9	8	5	4	6	6	9	6	8	6
1622-SL	8	10	4	5	6	7	8	7	9	6
1627-SL	9	12	5	6	6	7	8	7	9	6

* Suggested clearances and conditions can vary
 * All clearances are expressed in feet